



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

June 1, 2021

MISTER CRN CONSULTING INC.
PO BOX 488
MONTAGUE PE C0A 1R0
CANADA

Workorder Type: Registration - Fitting(Conventional)
Workorder No: SR3019828
Your Reference No.: LOG 2775
Registered to: AALBERTS INTEGRATED PIPING SYSTEMS APAC INC.SR3019828
Your Reference No.: LOG 2775
Registered to: AALBERTS INTEGRATED PIPING SYSTEM APAC INC.

Dear MILLER WEST,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN : 0C1968.75R2
Main Design No.: RENEWAL AND COMPANY NAME CHANGE – SEE CRN REGISTRATION DATED OCT 30, 2020 & SCOPE OF REGISTRATION
Expiry Date: Dec 18, 2030

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

The stamped copy of the approved registration and the invoice are mailed separately (There will be no hard copies for electronic submissions). Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Wendy Du
Engineer, BPV
Tel. : +1 416-734-3566
Email : Wdu@tssa.org



Technical Standards and Safety Authority
 345 Carlingview Drive
 Toronto, Ontario M9W 6N9
 www.tssa.org



**STATUTORY DECLARATION
 Registration of Fittings**

I, CHIU, YING - CHUAN, Plant Manager
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of Aalberts integrated piping systems APAC Inc.
(Name of Manufacturer)

Located at No. 295, Sec. 3, Wandan Road, Wandan Township, Pingtung, Taiwan 886-8-752-5877 886-8-753-0227
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME B31.3
(Title of recognized North American Standard)
 which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001:2015 which has been verified by the following authority, LRQA certificate No. ISO 9001 - 0068440

The items covered by this declaration, for which I seek registration, are category C type fittings. In support of this application, the following information and/or test data are attached as follows:
Renew 0C1968.75. See document "CRN Registration" dated Oct. 30, 2020, drawings & proof test records.
(drawings, calculations, test reports, etc.)

Declared before me at Kaohsiung in the Republic of China

the 20th day of November AD 2020

Commissioner for Oaths:
HUANG, CHI-RONG
(Printed name)
Huang, Chi-Rong
(Signature)

CHIU, YING CHUAN
(Signature of Declarer)

FOR OFFICE USE ONLY
 To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category _____

CRN: _____
 Registered by: _____
 Dated: _____

Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety Program

REGISTERED

C.R.N.: 0C1968.75R2
 Signed: [Signature]
 Date: June 1, 2021.

NOTE: This registration expires on: **DEC.18, 2030**

RENEWAL AND COMPANY NAME CHANGE - SEE CRN REGISTRATION DATED OCT 30, 2020 & SCOPE OF REGISTRATION

*Information provided in this application is releasable under the Freedom of Information and Privacy Protection Act and may be disclosed upon request.

SHURJOINT

STATUTORY DECLARATION

(Registration of Marriage)

1. I, the undersigned, being of legal age and sound mind, do hereby declare that the facts stated in the foregoing are true and correct.

2. I have read the foregoing and understand the contents thereof and the legal consequences thereof.

3. I have signed and affixed my seal to the foregoing and the same is true and correct.

4. I have signed and affixed my seal to the foregoing and the same is true and correct.

105-22-00000

105-22-00000

105-22-00000

105-22-00000

5. I have signed and affixed my seal to the foregoing and the same is true and correct.

6. I have signed and affixed my seal to the foregoing and the same is true and correct.

7. I have signed and affixed my seal to the foregoing and the same is true and correct.

8. I have signed and affixed my seal to the foregoing and the same is true and correct.

9. I have signed and affixed my seal to the foregoing and the same is true and correct.

Case No. : **109** Hsiung Yuan Ming Jen Chi Tzu No. **1183**
 Date : **NOV 20 2020**
 Attested at the Huang Chi-rong Notary Public Office, Taiwan
 Kaohsiung District Court, R.O.C. that signature(s)/seal(s) of
Chiu, Ting-Chuan in this document is/are authentic.
 Notary Public: Huang, Chi-rong
 > Huang, Chi-rong
 ADD: No.193, Dafeng 2nd Rd., Kaohsiung City 80774, Taiwan (R.O.C.)

CRN Registration

Oct. 30, 2020

Shurjoint Grooved Components are to be registered (Category C -Valves)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
SJ-C300 Butterfly Valve for Copper Tubing	2, 2½, 3, 4, 5, 6	150	EPDM: -4°F ~ +230°F (-20°C ~ +110°C)	AS-SJC300 ICKa ICKb ICKc
SJ-600 Ball Valve	1-1/2, 2, 2½, 3, 4	300	-20°F +230°F (-7°C +110°C)	AS-SJ600-a AS-SJ600-b 1SXa 1SXb 1SXc 1SXd 1SXe
SJ-400 Butterfly Valve	3, 4	250	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ400 ICNa ICNb ICNc
SJ-300N Butterfly Valve	2, 2½, 3, 4	300	EPDM: -4°F ~ +230°F (-20°C ~ +110°C)	AS-SJ300N 1J3a 1J3b 1J3c
RCV Riser Check Valve	2½, 3, 4, 5, 6	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-RCV 1RVa 1RVb 1RVc 1RVd 1RVe 1RVf
	8	125		
SJ-200 Low Profile Butterfly Valve	2, 2½, 3, 4, 6	125	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ2000 1JNa 1JNb 1JNc 1JNd

THIS IS PART OF CRN
 0C1968.75R2
 Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety
 Program

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
SJ-300F Resilient Seated Butterfly Valve	2½, 3, 4, 5, 6	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ300F AS-SJ300F-a 1JLa 1JLb 1JLc 1JLd 1JLe 1JLf 1JFi
SJ-500L Ball Valve	1½, 2, 2½, 3	250	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	SJ500-C-3
	4, 6	200		
SJ-900 Swing Check Valve	2½, 3, 4, 5, 6	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ900 1J9a 1RVb 1RVc 1RVd 1RVe 1RVf
	8	150		
SJ-930 Horizontal Swing Check Valve	2, 2½, 3, 4	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ930 1AJa 1AJb 1AJc AS-7771 H108a AS-XH70EP H1X8 G15a 7705TB 160a S819001
SJ-915 Dual Disc Check Valve	2½, 3, 4, 6, 8	300	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ915 AS-SJ915_b 1JKa 1JKd 1JKb 1JKc 1JKe
	10, 12	150		
	14, 16, 18, 20, 24	100		

THIS IS PART OF CRN

0C1968.75R2

Technical Standards and Safety Authority

Boilers and Pressure Vessels Safety
Program