

REGISTRATION OF A PRESSURE FITTING DESIGN

18-Mar-21

Mister CRN Consulting Inc.
PO Box 488
Montague, PEI
COA 1R0

Attention: Miller West

File Number: 11946 [0 F]

Re: Manufacturer: Aalberts integrated piping systems APAC Inc.

Item: Y-Strainers

Catalog or Drawing: Scope of Registration (Category E)

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations and CSA B51. The Canadian Registration Number (CRN) is:

0E1965.73

Expiry Date: December 18, 2030

Please note that every fitting shall be constructed in strict accordance with the registered design.

Fitting registrations are required to be resubmitted for validation after ten (10) years from the registration date in accordance with CSA B51, Clause 4.2.1.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Williams Uju, P.Eng.
Codes and Standards Compliance

Remarks:

CRN registered conditional upon compliance with the notes on the original registration.

A valid quality control program must be maintained at the production facility for the fitting registration to remain valid until the expiry date.

CRN Registration

Oct. 30, 2020

Shurjoint Grooved Components are to be registered (Category E - Strainers)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
726 Y-Strainer	2, 2½, 3, 4, 5, 6	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-726 166 160a 160c AS-7705B
	8	100		H105 AS-7771 H108b 68
	10, 12, 14, 16	75		G15a G15b 7705TB S819001
C726 Y-Strainer for Copper Tubing (CTS)	2, 2½, 3, 4, 6	150	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-C726 1CH 1C8 1C6 GC4 7705TB S819001
SS-726 Stainless Steel Y-Strainer	2½, 3, 4, 6	300	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SS726 1SP 1SQ As-SS8 G15a STB