


**UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS**

NEW BRUNSWICK  
NUNAVUT

NOVA SCOTIA  
YUKON

PRINCE EDWARD ISLAND  
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Aalberts Integrated piping systems APAC	
MANUFACTURERS ADDRESS: No. 295, Sec. 3, Wanda Road, Wanda Township, Pingtung, Taiwan R.O.C.	
PLANT LOCATIONS: As above	
<p align="center"><b>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</b></p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers                  B Flanges: all flanges                  C Valves: all line valves                  D Expansion joints, flexible connections, and hose assemblies: all types                  (E) Strainers, filters, separators, and steam traps                  F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters                  G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs                  H Pressure retaining components that do not fall into one of the above categories                  I Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	
TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3	
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <p align="center"> and / or <b>SHURJOINT</b></p>	
<p>TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/>                  CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>                  DESCRIBE OTHER</p>	
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <ul style="list-style-type: none"> <li>- LRQA certificate of approval No: ISO 9001 - 0068440</li> <li>- Renew 0E1965.7C.</li> <li>- See document "CRN Registration" dated Oct. 30, 2020, drawings &amp; proof test records.</li> </ul>	

**DECLARATION:**  
 I, CHIU YING - CHUAN (see note 3) employed by Aalberts Integrated piping systems APAC Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by LRQA certificate No. ISO 9001 - 0068440 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: CHIU YING CHUAN  
 Declared before me at Keelung  
 This 20th day of November AD 2020  
 Commissioner of Oaths or Notary Public: (sign) Jiang Chi-long

USE THIS SPACE FOR OFFICIAL SEAL

<p align="center">This space for Regulatory Authority use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of compliance.</p> <p>CRN: <u>0E1965.7 Rev2</u></p> <p>FID#: <u>16031</u></p> <p>Revision is CRN renewal and company name change from Shurjoint to Aalberts Integrated Piping Systems APAC Inc. Model C726, Notes: SS-726, 726 Y-Strainers.</p> <ol style="list-style-type: none"> <li>All fittings shall be registered in the name of the Manufacturer.</li> <li>Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.</li> <li>The declaration shall be made by the person having full authority and responsibility for the quality of the end product.</li> <li>Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.</li> </ol>	<p align="center">NOVA SCOTIA                  BOILER &amp; PRESSURE VESSEL                  Date <u>Dec. 18/20</u>                  C.R.N. <u>0E1965.78REV2</u>                  Dwg. <u>as described</u>                  Signed <u>Yvonne Perry</u>  <u>1 of 1</u>                  Part                  ACT &amp; REGULATIONS</p> <p align="right">Sect. 1.0 - Fittings Rev. 1 06/2003</p>
--	---

# CRN Registration

Oct. 30, 2020

Shurjoint Grooved Components are to be registered (Category E - Strainers)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
726 Y-Strainer	2, 2½, 3, 4, 5, 6	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-726 166 160a 160c AS-7705B
	8	100		H105 AS-7771 H108b 68
	10, 12, 14, 16	75		G15a G15b 7705TB S819001
C726 Y-Strainer for Copper Tubing (CTS)	2, 2½, 3, 4, 6	150	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-C726 1CH 1C8 1C6 GC4 7705TB S819001
SS-726 Stainless Steel Y-Strainer	2½, 3, 4, 6	300	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SS726 1SP 1SQ As-SS8 G15a STB