



## Certified Product Listing

**For:**

Drinking Water System Components - Health Effects

**Company:**

Aalberts integrated piping systems APAC Inc.  
No. 295, Sec. 3, Wandan Rd.  
Wandan, Pingtung, Taiwan

**Plant Location:**

Siaogang District, Kaohsiung City, Taiwan

**Standards:**

NSF/ANSI/CAN 61 - 2022  
NSF/ANSI/CAN 372 - 2022

**Certificate:**

Issued Date: 02/23/2023

**Material/Product:**

Shurjoint Gasket

**Contact Temperature:**

82 ± 2°C

**Models:**

Grade E1 EPDM Fast-Fit Gasket (3/4" - 8") \*  
Grade E1 EPDM Flange Gasket (2" - 24") \*  
Grade E1 EPDM Flange Gasket (for copper tubings) (2" - 8") \*  
Grade E1 EPDM GapSeal Gasket (1-1/4" - 24") \*  
Grade E1 EPDM GapSeal Gasket (for copper tubings) (2" - 8") \*  
Grade E1 EPDM Mechanical Tee Gasket (2-1/2"x1/2" - 4"x1-1/4") \*  
Grade E1 EPDM Reducing Gasket (2"x1-1/2" - 8"x6") \*  
Grade E1 EPDM Standard Gasket (3/4" - 24") \*  
Grade E1 EPDM Transition Gasket (2" - 6") \*  
Grade EHM EPDM Standard Gasket (2" - 8") \*

\* Certified for use with Glacier 200 FCC/USP or Mistrion 403 talc powders